



**Government of West Bengal**  
**Office of the Divisional Fire Officer**  
**West Bengal Fire & Emergency Services**  
**430, G.T. Road, Howrah(N), Pin :- 711101**

**Memo No.:FSR/IND/WB/FES/20192020/60131**

**Date : 24-09-2024**

**From :**  
**Divisional Fire Officer**  
**Howrah Division,**  
**West Bengal Fire & Emergency Services**

**To :**  
**SAMARITAN MISSION SCHOOL**  
**Dag No-111,112,112/2048,L.R.-118-120,L.R.KH-9894,Mou-Bankra,J.L.-55,P.S.-Domjur,Howrah Amta Road, Bankra**  
**Kabarpara,Howrah F.S.,Domjur, Howrah- 711403**

**Sub : Sub: Fire Safety Certificate of EXISTING G+5 STORIED SCHOOL BUILDING UNDER GROUP OF 'EDUCATIONAL OCCUPANCY' in the name & style of "SAMARITAN MISSION SCHOOL" at the premises :- DAG NO-111,112,112/2048, L. R.-118-120, L.R.KH-9894, MOU-BANKRA, J.L.-55, P.S.- DOMJUR, HOWRAH AMTA ROAD, BANKRA KABARPARA, DOMJUR, HOWRAH-711403,This is in reference to your application AIN -211892406300002303 Dated - 8-Sept-2024. Regarding the Fire Safety Certificate for of EXISTING G+5 STORIED SCHOOL BUILDING UNDER GROUP OF 'EDUCATIONAL OCCUPANCY' in the name & style of "SAMARITAN MISSION SCHOOL", at the premises :- DAG NO-111, 112,112/2048, L.R.-118-120, L.R.KR-9894, MOU-BANKRA, J.L.-55, P.S.- DOMJUR, HOWRAH AMTA ROAD, BANKRA KABARPARA, DOMJUR, HOWRAH-711403.**

This is in reference to your AIN 211892406300002303 dated 08-Sep-2024 regarding Sub: Fire Safety Certificate of EXISTING G+5 STORIED SCHOOL BUILDING UNDER GROUP OF 'EDUCATIONAL OCCUPANCY' in the name & style of "SAMARITAN MISSION SCHOOL" at the premises :- DAG NO-111,112,112/2048,L.R.-118-120,L.R.KH-9894,MOU-BANKRA, J.L.-55,P.S.- DOMJUR, HOWRAH AMTA ROAD, BANKRA KABARPARA, DOMJUR, HOWRAH- 711403,This is in reference to your application AIN -211892406300002303 Dated - 8-Sept-2024. Regarding the Fire Safety Certificate for of EXISTING G+5 STORIED SCHOOL BUILDING UNDER GROUP OF 'EDUCATIONAL OCCUPANCY' in the name & style of "SAMARITAN MISSION SCHOOL" at the premises :- DAG NO-111,112,112/2048,L.R.-118-120,L.R.KH-9894,MOU-BANKRA, J.L.-55,P.S.- DOMJUR, HOWRAH AMTA ROAD, BANKRA KABARPARA, DOMJUR, HOWRAH- 711403..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Fire Safety Certificate** for occupancy of the aforesaid building.



*Rebecca*  
*Signature*  
**Medical Officer**  
**Rebecca Belious Charitable Dispensary Hospital**  
**234, Belious Road, Howrah- 711101**  
**West Bengal, India**

*Mohammed Khair Nawaz*  
**Secretary**  
**SAMARITAN MISSION SCHOOL**  
**KABARPARA, BANKRA**  
**HOWRAH - 711403**

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892406300002303



## Recommendation:

The performance of the Fire Fighting System as incorporated in the aforesaid building was tested random and found satisfactory working condition during inspection. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety measure, the following safety measures need to be incorporated.

- 01) Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
  - 02) All the Entrance and Exits as marked in the sanctioned plan drawing must be opened and free from any type of obstruction.
  - 03) The interior finish decoration of aforesaid premises shall be made with low flame spread material confirming to the I.S. Specification.
  - 04) To eliminate risk of Fire Hazards, Good House Keeping both for insides and outsides of the aforesaid premises shall be strictly maintained.
  - 05) Existing Electrical wiring of the whole aforesaid premises shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
  - 06) A Fire Control Room including a closed circuit T.V. system will have to be maintained which observe all floor of the aforesaid premises.
  - 07) The notice of Fire Fighting and Evacuation from the aforesaid premises shall be prepared and displayed at all vulnerable of the Aforesaid premises.
  - 08) The Employees and Security Staff shall be conversant with installed Fire Fighting equipment's of the aforesaid premises and to operate in the event of Fire and Testing.
  - 09) Mock Fire Practice and Evacuation Drill shall be performed periodically with participants of all the occupants of the aforesaid premises.
  - 10) Transformer and Switch gear shall be protected with automatic CO2 or D.C.P. Fire extinction confirming I.S. Specification.
  - 11) A Crew of Trained Fireman under an Experienced Officer shall be maintained round the clock for safety of the aforesaid premises.
  - 12) The system of Auto shut down of A.H.U. shall be incorporated with the Auto Detection & Alarm system.
  - 13) First- Aid Fire Fighting system shall be provided as per I.S. Specification.
  - 14) Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
  - 15) If required the old electrical lines shall have to be replaced with new lines. The cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
  - 16) Periodical flashing of water in the Hydrants and Sprinkler pipe lines shall be made to maintain the efficiency working performance of above mention system.
  - 17) All Fire pumps, Alarm and detection system which are incorporated in the building shall be kept in auto mode round the clock.
  - 18) Fire safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.
  - 19) Adequate numbers of Fire Escape mask shall be provided of the building.
  - 20) The Head of the organization/Society as the case may be, shall submit a declaration to the Director General, West Bengal Fire & Emergency Services on every 1<sup>st</sup> April, 1<sup>st</sup> July, 1<sup>st</sup> October & 1<sup>st</sup> January maintaining financial calendar that "The Fire Prevention and Fire Safety Measures in the building or premises have been tested and are in good working condition. That, no material changes has been done in the building that has affected the Means of Escape and Means of Access as the case may be. That, all the members of the organization are well conversant with the Evacuation Drill and mentally & physically fit to combat the Fire Emergencies. That, any deviation in the above and failure in maintenance of the Fire Prevention and Fire Safety measures shall at the risk and liability of the Head of the organization / Society.
- This FIRE SAFETY CERTIFICATE is valid for 03(Three) years from the date of issuance of This Certificate. After three year a Renewal Fire Safety Certificate is to be obtained from the Director General, West Bengal Fire & Emergency



*Arshad*  
*S. J. Sana*  
Medical Officer  
Rebecca Belilious Charitable Dispensary Hospital  
234, Belious Road, Howrah - 711101  
West Bengal, India

*Mohammed Khairul Nawaz*  
Secretary  
SAMARITAN MISSION SCHOOL  
KABARPARA, BANKRA  
HOWRAH - 711403




performance of all the Life & Fire Safety arrangements & Installations of the Building.

Valid Upto : 23-Sep-2027

# Memo

## No.:FSR/IND/WB/FES/20192020/60131

  
Medical Officer  
Rebecca Belilious Charitable Dispensary Hospital  
234, Belilious Road, Howrah - 711101  
West Bengal, India



Secretary  
SAMARITAN MISSION SCHOOL  
KABARPARA, BANKRA  
HOWRAH - 711403



Signature valid

Digitally Signed.  
Name: RANJAN KUMAR GHOSH  
Date: 24-Sep-2024 22:43:29  
Reason: D-Sign  
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892406300002303